



Franklin Fire Department Codes

- a. 8' (minimum) **aisle ways** must be maintained on mezzanine and arena floor levels
- b. 3' clearance around all **fire extinguishers**
- c. all **exit doors** (glass doors) must be clear of obstructions (no vendors in lobby).
- d. All **STROBES, EXIT SIGNS** and **EMERGENCY LIGHTING** must remain visible and clear of obstructions. **Pipe and Drape** must be 6' 6" or less on the mezzanine level....arena level pipe and drape is not restricted.
- e. Can NOT block aisle ways (stairs) to/from **seating areas**
- f. **Tents:** Must be flame resistant and permitted
- g. No Burning **Candles**
- h. Any **motor vehicle** parked inside the main building can have no more than 5 gallons of gasoline in it's tank, and must have a locking gas cap or cover. **Battery cable** must be disconnected.
- i. All **FIRE HYDRANTS** must remain accessible and free of obstructions.
- j. **Generators** must be inspected and permitted.
- k. Pine Needles are not allowed within any Ag Expo Park building.

Your Event will be subject to fines or CANCELLATION if these conditions are not complied with and approved by the City of Franklin's Fire Department officials.

***For more information, please call the Franklin Fire Department
@ 615-791-3270, or the Williamson County
Ag Expo Park @ 615-595-1227***